



हरियाणा अग्निशमन सेवायें, झज्जर



Subject: - Fire Safety Certificate from the Fire Safety Point of View of the Educational Building (Group-B) at Village-Machhrauli, Distt Jhajjar, Haryana of M/s P.M. Shree Govt. Sr. Sec. School.

M/s P.M. Shree Govt. Sr. Sec. School has submitted the case cited above for the Fire Safety Certificate through transaction id- 070442423000082 dt.- 22.06.2024. The team of fire station officers has inspected the site on dated 22.06.2024 and tested the fire system, means of escape in aforesaid building and found that the Fire Fighting Systems and means of escape in said building are found in good working condition as per provision of National Building Code of India Part - IV 2016. The detail of building and fire system installed therein is given below: -

Building Detail:-

1. Name of Building :- M/s P.M. Shree Govt. Sr. Sec. School
2. Address :- Machhrauli, Distt. Jhajjar
3. Plot Area. :- 22521.85 SQM
4. Type of Occupancy :- Educational Building (Group-B)
5. Permissible Height :- 30 mtrs
6. Basement Detail :-

Tower No. / Name	Basement Level	Basement Area	Remarks
N/A	N/A	N/A	N/A

Building Detail:-

Tower No. / Block	Floor Area (Ground Coverage)	No. of Floor	Occupied Height	Stair Case		
				Min As per NBC	As per Travel Distance	Provided
Block A	1515.71 Sqm	G+1	9.2 mtrs	2	Less than 30 mtrs proposed	1
Block B	505.35 Sqm	GF	4.4 mtrs	-	Less than 30 mtrs proposed	-
Block C	326.80 Sqm	GF	4.4 mtrs	-	Less than 30 mtrs proposed	-

Name of Occupancy - Educational Building (Group-B)

S. No	Norms as per NBC, 2016	Required as per Approved Plan	Provision provided	Photo Attach
1.	Fire Extinguishers	Yes	Yes	Yes
2.	Hose Reel	Yes	Yes	Yes
3.	Dry Riser	N/A	N/A	N/A
4.	Wet Riser	N/A	N/A	N/A
5.	Down Comer	N/A	N/A	N/A
6.	Yard Hydrant	N/A	N/A	N/A
7.	Automatic Sprinkler system	N/A	N/A	N/A
8.	M.C.P.	N/A	N/A	N/A
9.	Automatic Detection & Alarm System	N/A	N/A	N/A
10.	U.G. Water Tank	N/A	N/A	N/A
11.	Terrace Tank	Yes	Yes 10KL for Block A, B & C	Yes
12.	Pumps near UG Tank (In LPM)	N/A	N/A	N/A

Government of Haryana

AH ested
Principal
PM Shri Govt.
Sr. Sec. School,
Machhrauli (JJR)

Scanned with CamScanner



Fire Safety Certificate from the Fire Safety Point of View of the Educational Building (Group-B) at Village-Machhrauli, Distt Jhajjar, Haryana of M/s P.M. Shree Govt. Sr. Sec. School

13.	Terrace Pump	Yes	Yes 450LPM for Block A, B & C	Yes
14.	Domestic Tank is connected with overflow of Fire Tank.	Yes	Yes	See Sr. No-11
15	Smoke Exhaust/Fresh Air System in Basement	N/A	N/A	N/A
16	Means of Escape/Signage	Yes	Yes	Yes 16/A
17	Pressurization Fan Lift	N/A	N/A	N/A
18	Louvers/Pressurization of staircase	N/A	N/A	N/A
19	Basement Compartmentation	N/A	N/A	N/A

The case has been examined by Fire Officer on the basis of photographs of the building/system mentioned above viz-a-viz approved Fire Fighting Scheme, National Building Code 2016 Part-IV and the Haryana Fire and Emergency Services Act, 2022. After examination, it is recommended that Fire Safety Certificate may be issued subject to the following conditions:-

- i. The owner/occupier shall appoint duly trained Fire Safety Officer along with Fire Staff round the clock in building.
- ii. All the firefighting equipments shall be maintained in perfect working condition every time. If any lapse is found in the fire protection system at the time of inspection or noticed during outbreak of fire, action will be taken against owner/occupier as per the provision of Haryana Fire and Emergency Services Act, 2022 and rules.
- iii. The owner/occupier shall apply for Renewal Fire Safety Certificate 2 month prior to expiry of this Fire Safety Certificate on www.Saralharyana.gov.in portal.
- iv. The open set back area is not checked by Inspecting team of Fire Station and the same shall be checked by concerned building authority/department.
- v. The owner/occupier shall strictly follow all other applicable rules/regulations/byelaws laid down regarding fire safety system. If owner/occupier fail to comply with any of the above terms & conditions, he will be liable to be punished as per Section 30,31 & 47 of Haryana Fire & Emergency Services Act 2022.
- vi. The owner/occupier shall perform quarterly Fire Drill in his building as per provision of National Building Code under intimation to Fire Department and videography evidence to be kept as a record which shall be produced at the time of next Renewal of Fire Safety Certificate. The Residents/R.W.A. shall be involved in the said Fire drill.
- vii. If the Infringements of Byelaws remains un-noticed, the Authority reserves the right to amend the Fire Safety Certificate as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.

Government of Haryana

(Signature)
Principal
PM Shri Govt.
Sr. Sec. School,
Machhrauli (JJB)

Scanned with CamScanner



हरियाणा अग्निशमन सेवायें, झज्जर



Fire Safety Certificate from the Fire Safety Point of View of the Educational Building (Group-B) at Village-Machhrauli, Distt Jhajjar, Haryana of M/s P.M. Shree Govt. Sr. Sec. School



- viii. The owner/occupier shall submit a self-declaration certificate every year to the effect that the firefighting system installed in his building is in good working condition and there is no addition/alteration in the building. The Fire Official may randomly check such building.
- ix. In case there is any addition/alteration beyond permissible limit under the Haryana Building Code, 2017, the Fire Safety Certificate shall be seized to exist and the owner shall apply for approval of revised Fire Fighting Scheme as per the section 18 of Haryana fire & Emergency service Act, 2022.
- x. Any deviation with regard to construction, ventilation, occupation, Electrical Installation etc. may be got verified from the concerned authorities. In case of deviation the fire safety certificate shall be treated as Null & Void.
- xi. The fire safety certificate shall never be treated for the purpose of regularization of unauthorized construction.
- xii. This Fire Safety Certificate is valid for Five years for Residential building (A1 to A4) and three years for other than residential buildings (A1 to A4) from the date of issuance of this certificate in accordance with sub section 4 of section 19 unless renewed under section 20 or sooner cancelled under section 21 of Haryana fire & emergency service Act, 2022.

It is mentioned here that approval of firefighting scheme already stands approved vide letter No. FS/2023/923 dated 18.08.2023 and the building is Government Building and verified by Tehsildar, Jhajjar (Haryana).

Fire system provided as per guideline of NBC norms & the case is fit for approval/ sanction please.


Fire Station Officer,
Jhajjar

W/Dy. Director (Tech)



Principal
PM Shri Govt.
Sr. Sec. School,
Machhrauli (JJR)

Scanned with CamScanner


Scanned with CamScanner

Fire Safety - Undertaking

Category of application : Fresh affiliation upto Senior Secondary level Switch over from other Boards (only schools who are already affiliated to another Board)

I, RAJ KUMAR, Principal of the school PM SHRI GSSS MACHHRAULI do hereby undertake that the school run/applied under regular category is unable to obtain / renew Fire Safety Certificate issued from the Fire Safety Department of the State Government/ Competent Government Authority eg. Municipal Corporation etc. of the concerned area till date of application. The school was last inspected for the fire safety on : 22/06/2024

I, assure that before starting of the regular school/commencement of session the above safety certificate will be obtained and submitted. In the meanwhile whole responsibility of the safety and security of staff and students will be on undersigned. Therefore, being a regular category school it may be provisionally allowed.



Principal

PM Shri Govt. : 17
**Sr. Sec. School,
Machhrauli (JJR)**

Principal Sign :

Principal Name :

RAJ KUMAR

School Address :

Date :

25-6-2024

Place :

MACHHRAULI

Seal :

Principal
PM Shri Govt.
**Sr. Sec. School,
Machhrauli (JJR)**